



Performance Annual Report

I. General Information

Facility / System Name: Faison Wastewater Treatment Facility

Responsible Entity: Town Of Faison

Person in Charge/ Contact: William O Mello (910-379-5025)

Applicable Permit(s): WQ0003661

Description of Collection System or Treatment Process: Operation of a 255,000GPD wastewater treatment facility consisting of a 25,000 gallon Chlorine contact chamber, inlet rotating bar screen, bypass manual bar screen, 56 acre solid set spray irrigation system, (1) 16 acre center pivot, 3 facultative/ storage lagoons and pump station with (2) 800GPM vertical turbine pumps. The collection system consisting of 7 pumping stations. The facility is located at 188 Water Treatment Rd.

II. Performance

Text Summary of System Performance for Calendar Year:
Exceeded flow limit for the month of October and April

List (by month) any violations of permit conditions or other environmental or other regulations. Monthly listed should include discussion of any environmental impacts and corrective measures taken to address violations.

October- Exceeded daily flow limit due to 13.5inches of heavy rain from hurricane Matthew on the 8th and 9th of October.

April- Exceeded daily flow limit due to 6inches of heavy rain on the 24th and 25th of April

III. Notifications

Notification is posted at Faison Town Hall, Faison Recreation and wellness Center, and Faison Library.

IV. Certification

I certify under penalty of law that this report is complete and accurate to the best of my knowledge. I further certify that this report has been made available to the users or customers of the named system and that those users has been notified of its availability.

William O Mello
Title: Assistant Public Works Director / ORC of Wastewater

May 11, 2017