



2024

Performance Annual Report

I. General Information

Facility / System Name: Faison Wastewater Treatment Facility

Responsible Entity: Town of Faison

Person in Charge/ Contact: William O Mello (910-379-5025)

Applicable Permit(s): WWP-WQ0003661 CS-WQCS00172

Description of Collection System or Treatment Process: Operation of a 255,000GPD wastewater treatment facility consisting of a 25,000-gallon Chlorine contact chamber, inlet rotating bar screen, bypass manual bar screen, 56-acre solid set spray irrigation system, (1) 16-acre center pivot, 3 facultative/ storage lagoons and pump station with (2) 800GPM vertical turbine pumps. The collection system consisting of 7 pumping stations. The facility is located at 188 Water Treatment Rd.

II. Performance

Text Summary of System Performance for Calendar Year: System performed exceptionally well this year with no violations.

III. Notifications

Notification is posted at Faison Town Hall, Faison Recreation and wellness Center, Faison Library and also available on the Town of Faison website. (www.faisonnc.org)

IV. Certification

I certify under penalty of law that this report is complete and accurate to the best of my knowledge. I further certify that this report has been made available to the users or customers of the named system and that those users has been notified of its availability.